

CERTIFICATE OF COMPLIANCE & ORIGIN

This letter is to certify that Alan Wire's solid soft drawn and concentrically stranded soft drawn bare copper meets ASTM standard B-3 and B-8 for soft drawn (annealed) solid or stranded bare copper wire. Conductors may also be constructed to meet ASTM B-787.

Alan Wire THHN/THWN-2 building wire products meet all applicable ASTM standards, UL Standard 83, UL Standard 1063, CSA C22.2 No. 75, and the requirements of the National Electrical Code. Alan Wire's THHN/THWN-2 (1/0-750 MCM) is CT rated for CT use.

Alan Wire Type TC Power & Control cable meets UL 1277 & all applicable requirements of the National Electrical Code.

Alan Wire XHHW-2 products meet UL44, CSA C22.2 No. 38, and all applicable requirements of the National Electrical Code. USE-2 meets UL 854 and requirements of the NEC.

All Alan Wire insulated products are RoHS & REACH Compliant.

All Alan Wire products are compliant with the Dodd-Frank Act and contain no conflict minerals.



830 South West Street / Sikeston, MO 63801
800.325.8050 / F: 800.622.3355